

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 85Dated: 18/04/24


It is certified that an inspection team headed by Dayalu Rothod
(Name of Officers with designation) from S. D. O. P. H. E. Jhabua
PHED inspected the **New Way Public School, Jobat Naka, Rampura, Ranapur, Dist.- Jhabua (M.P)**
on 20/3/2024 and on the basis of Water Test Report (Attached) bearing no. 3263
dated 26/3/24 of PHED Jhabua Lab. (PHED
Lab) certified that the **New Way Public School, Jobat Naka, Rampura, Ranapur, Dist.- Jhabua
(M.P)** has safe drinking water facilities for the students and members of staff of the institution. School
is also maintains the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 18/4/25


**PRINCIPAL
NEW WAY PUBLIC SCHOOL
RANAPUR (M.P)**

To,
New Way Public School,
Jobat Naka, Rampura, Ranapur, Dist.- Jhabua (M.P)

(Name and address of the institution)

Signature with seal: 
Assistant Engineer
Public Health Engineering
Sub-Division, JHABUA
Name: Dayalu Rothod
Designation: S. D. O. P. H. E. Jhabua
Name & address of the office/Department: - P. H. E. D.


सचिव
न्यू वे पब्लिक स्कूल
राणापुर जिला-झाबुआ(म.प्र.)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

(30)

PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER QUALITY TESTING LABORATORY


PUBLIC HEALTH ENGINEERING DIVISION JHABUA -457661


Sample Received From Analysis Report No. 3263.....
 न्यू वे पब्लिक स्कूल Bill No. 147 date .. 20/03/2024 ..
 रानापुर Particulars of Collection
 Date of Collection ... 20/03/2024.....
 Date of Receipt 20/03/2024.....
 date of Analysis .. 26/03/2024.....

Description of Sample :-


- (i) विकासखण्ड रानापुर - न्यू वे पब्लिक स्कूल रानापुर
- (ii) _____
- (iii) _____
- (iv) _____
- (v) _____

S No.	Parameters	Unit & permissible limit as per BIS 10500-2012	Value Obtained					
			(i)	(ii)	(iii)	(iv)	(v)	
(A)	PHYSICAL							
1	Colour	5 TO 15 HAZEN	-					
2	Taste	Agreeable	-					
3	Odeur	Unobjectional	-					
	Turbidity	1 to 5 NTU	1.2					
(B)	CHEMICAL							
5	pH	PH SCALE (6.5 to 8.5)	7.2					
6	Specific Conductivity	Micro mhos / Cm.	-					
7	Total Dissolved Solids	500-2000 mg/l	57					
8	Total Hardness(as Co Ca3)	300-600 mg/l	22					
9	Total Alkalinity	200-600 mg/l	33					
10	Chlorides (as Cl)	250-1000 mg/l	14					
11	Fluoride (as F)	1.0-1.5 mg/l	0.50					
12	Nitrate (as NO ₃)	45 mg/l	4.43					
13	Iron (Fe)	Nil mg/l	0.08					
14	Residual Chlorine	0.2-1.0 mg/l	0					
15	Sulphate	200-400 mg/l	2.1					
16	manganese	0.1-0.3 mg/l	0					
17	Arsenic	0.01-0.01 mg/l	-					
18	BACTERIOLOGICAL							
(C)	Total Coliform /100 ml.	Nil	-					
19	Faecal Coliform /100 ml.	Nil	-					
(D)	OTHER TEST							


 सचिव
 न्यू वे पब्लिक स्कूल
 रानापुर जिला-झाबुआ(म.प्र.)


PRINCIPAL
 NEW WAY PUBLIC SCHOOL
 RANAPUR (M.P.)

नोट: प्राप्त परिणाम BIS 10500 - 2012 के अनुसार निम्नीलि सिमा में पाये गये है।


Chemist
 W.T.L. PHE, Dn. JHABUA